

Bulletin 0-3-2

Errors and omissions in 2009 Ontario Electrical Safety Code

0

Issued January 2010
Supersedes Bulletin 0-3-1

Scope

The intent of this Bulletin is to recognize errors and omissions in the 2009 Ontario Electrical Safety Code. Please, mark in your Code Book.

- (1) Section 10
- (2) Section 12
- (3) Section 14
- (4) Section 18
- (5) Section 58
- (6) Section 75
- (7) Tables
- (8) Appendix B
- (9) Appendix J

(1) Section 10

Rule 10-618

Add "(see Appendix B)" to title.

(2) Section 12

Rule 12-112(5)(b)

The reference to Rule 12-112(5)(b) should read "notwithstanding the requirements of Subrule (3) (4)..."

(3) Section 14

Rule 14-418

Add "(see Appendix B)" to title.

(4) Section 18

Rule 18-004

Add "(see Appendix B)" to title.

(5) Section 58

Rule 58-000

Add "(see Appendix B)" to title.

Rule 58-300

Add "(see Appendix B)" to title.

(6) Section 75**Rule 75-604**

The reference to “Rules 30-100 to 30-1036” should read “Rules 30-1000 to 30-1036.”

Rule 75-606 (2)

The reference to “as specified in Table 10” should read “as specified in Table 19.”

(7) Tables**Table 17**

Revise reference rules to read “(See Rules 10-700 and 10-812).”

Table 19

Under Conditions of use “For service entrance above ground” and Trade designation “Armoured cable”, reference note 16 applies to AC90, not ACWU90.

(8) Appendix B**Appendix B note to Rule 14-418**

The term “unit” refers to individual areas such as found in shopping malls, or similar areas. The term unit does not apply to the breakdown of office space in office towers to accommodate various tenants.

Appendix B note to Rule 18-150

Delete note that reads “Rule 18-150 A group of three fuses protecting...”

Appendix B note to Rule 18-150(2)(e)


Revise note to read “Rules 18-150(2)(e), 18-210, 18-260, 18-308, 18-358 See the Note to Rule 18-114.”

Appendix B note

Delete note that reads “Rules 18-150, 18-210, 18-260, 18-308, 18-358 See the Note to Rule 18-114.”

Appendix B note Rule 68-054

The figure should be replaced with the following (the correction is identified in the circle):



Appendix B note to Rule 68-068

Revise title for note to rule 68-068 to read "Rule 68-068(6)."

0**Appendix B note to Rule 68-306**

Revise title for note to rule 68-306 to read "Rule 68-306(2)."

(8) Appendix J**Diagrams JD-6 & JD7**

Revise diagram references to Zone 1 & 2 to read Division 1 & 2 respectively.